


SITE INSPECTION AUDIT REPORT

Consent No: **BC171402**
Applicant: **Frost Ronald Barrymore**
Site Address: **186 Summerhill Road SUMMERHILL**
Work Type: **WOODSMAN TARRAS MK111 WETBACK FREESTANDING LOGBURNER CLEAN AIR CERT 143494 186 SUMMERHILL ROAD SUMMERHILL LOT 7 DP 469532**

Building Name:
Location within site:
Level Unit Number:
Building Category: **R01**

Inspection Type: **Heating Unit / Boiler Final**
Inspection Outcome: **Pass**
Inspected By: **John Thornton**
Inspection Date: **23 May 2018 12:12 p.m.**
Duration: **30 minutes**

Inspection Element	Status
General Items	Pass
Health and Safety requirements	N/A
Standard WDC uniform Hi-Vis shirt/jacket worn on site.	
Standard safety footwear required and worn on site.	
Approved Building Consent on site	Pass
Inspection Items	Pass
Unit clearances	Pass
-160mm minimum distance achieved to rear combustible wall material, although 460mm minimum side wall clearances to combustible wall material are not achieved.	
23/5/18: Side walls shielded with fibre cement sheets on rondo metal battens spaced 32mm from combustible surfaces vented top & bottom. Using reduction factor of .3 x 460mm =138mm required, distances are 365mm to LHS and 385mm to RHS.	



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 11:59 AM on Wednesday 23/05/2018



Taken at 12:01 PM on Wednesday 23/05/2018