

---

**SITE INSPECTION NOTICE**

---

Consent No: **BC171402**  
Applicant: **Frost Ronald Barrymore**  
Site Address: **186 Summerhill Road SUMMERHILL**  
Work Type: **WOODSMAN TARRAS MK111 WETBACK FREESTANDING LOGBURNER CLEAN AIR CERT 143494 186 SUMMERHILL ROAD SUMMERHILL LOT 7 DP 469532**  
Building Name:  
Location within site:  
Level Unit Number:  
Building Category: **R01**

---

Inspection Type: **Heating Unit / Boiler Final**  
Inspection Outcome: **Pass**  
Inspected By: **John Thornton - 021 543 919**  
Inspection Date: **23 May 2018**

**Passed Items**

## General Items

Approved Building Consent on site

## Inspection Items

Unit clearances

**-160mm minimum distance achieved to rear combustible wall material, although 460mm minimum side wall clearances to combustible wall material are not achieved.**

**23/5/18: Side walls shielded with fibre cement sheets on rondo metal battens spaced 32mm from combustible surfaces vented top & bottom. Using reduction factor of .3 x 460mm =138mm required, distances are 365mm to LHS and 385mm to RHS.**

---

**Documentation**

Application form for CCC (Form 6)  
(Serv.) Heating Unit Installation Checklists (PS3)

**Status**

Accepted  
Accepted