

6 May 2020



Brady Drainage
P O Box 552
WHAKATĀNE 3158

By e-mail: **bradydrainage@xtra.co.nz**

Dear Ryan

WASTEWATER PERMIT FOR 60 POHUTU STREET

You are hereby authorised to install a Wastewater connection to the Public Sewer Main for the above property in accordance with Whakatāne District Council's Engineering Code of Practice and subject to the conditions listed below. The new lateral should be 150mm as specified on your submitted plan, rather than the 100mm specified on the Engineering Code of Practice standard. There must be an inspection point at the boundary of the property.

You will require this letter in order to make payment of the following at the Council's Customer Service Centre. Please only pay this inspection fee after the connection has been installed:

- New Connection Inspection Fee - \$ 165.00 (GST inclusive)

Conditions for making a connection:

1. The relevant Thee Waters Operations Inspection fee is paid (as above).
2. Connections shall be carried out by a Registered Drainlayer. The work shall be carried out in accordance with the provisions of the WDC's Engineering Code of Practice i.e. Standard Drawing SS08, best work practices and the drawings submitted.
3. The applicant shall be responsible to obtain the neighbour's approval for the work that will be carried out inside the neighbour's property and shall also be responsible for reinstating the trench and surface cover i.e. grass, concrete pavement etc.
4. If the Council's main wastewater main, or manhole is under/on a Road or Road Reserve work cannot commence without the Work Access Permit Approval from Council's Roading Engineer. Application for Work Access Permit is available at the Customer Service Desk.

5. Upon completion of work, contact the Three Waters Operations Coordinator (Thomas King Hazel) to book for an inspection. All connections shall be inspected by Three Waters Operations Coordinator or his representative prior to backfilling; please note that connection must be exposed at the time of inspection. A minimum of two days prior notice should be given when booking for an inspection date.
6. Provide an as-built plan prepared by the registered drainlayer to the Three Waters Operations Coordinator during the inspection. The 'as-built' plan must clearly identify the location of the connection and must show measurements from the boundaries
7. If the work has been found to be carried out as per the acceptable standards mentioned above, an Inspection Report with approval signed by Council's Three Waters Operations Technical Representative will be issued. Otherwise, the customer will be issued with the inspection report listing items to be rectified and is advised to contact the Customer Services Officer to organise another inspection time. Please note that each inspection incurs a fee and must be paid when booking for an inspection schedule.

This permit will expire 6 months after issue. If you wish to proceed after then, it will be necessary to make a new application.

Yours sincerely



Viv Hynds
THREE WATERS ADMINISTRATOR
WHAKATĀNE DISTRICT COUNCIL
P 07 306 0500 Ext 7701 F 07 307 0718
E Viv.Hynds@whakatane.govt.nz W www.whakatane.govt.nz
Commerce Street, Private Bag 1002, Whakatāne 3158, New Zealand