

Date 01.07.2020
Asset Reg 2021-002

Three Waters Asset Data Collection Checklist

The purpose of this checklist is to ensure asset data is updated into the relevant asset management systems and tracked to speedy timeframes. This checklist also acts as a control for validation and approval to change asset data from owners of the relevant asset management systems.

Attention:

☐

Asset Mgr, Utilities

☐

Asset Mgr, Community Facilities

☐

Asset Mgr, Transportation

Address Of Asset: **60 Pohutu Street**

Whakatāne

☐
☐

Water meter

Please Ensure the relevant asset data documents are **attached**

As-built Supplied

Project Completion Report(including retirement schedule)

SAM 82587

RFS 188428

Date	System to be Updated/Validated	Ref No	Signed	Date Updated	Quality Check
01.07.2020	SAM		Viv Hynds	21.07.2020	
	GIS		Viv Hynds	21.07.2020	
	Ozone Co-ordinates 1950123.671/5791967.921		Bev		
	OZONE				
	Property Database				
	Drawing Register				

INSTALLED WATER METER

NEW METER SERIAL NUMBER

20MC267917

Reading

0

Asset Data Verified By Asset Manager

Asset Data Verified By Asset Manager

Asset Data Verified By Asset Manager

Date

Date

Date

Please return to Leilani @ Utilities by

WHAKATANE DISTRICT COUNCIL - DEPOT
NEW WATER METER INSTALLATION

Asset **WMTR** RFS No **188428**

Asset No/Unit No **WM** Account No

Activity **WMNEWC** **WATER/NEW CONNECTIONS**

Reported by **RAYNES BARRY** Phone **cel 0064 021 2423778**

Site Address **60 POHUTU STREET** Rep't Time/Date **09:02a.m./30 Jun 2020**

Source **WATER** Maintenance type W/Order **N 82587**

Call Details

Payment for new connection has been received back 9/6 - but unfortunately not scheduled for install. 2020/212304. Please install as soon as possible.

Further Details

LABOUR Start Time **1330-1630** AM/PM

Date	ID	STD	T1½	T2	Date	ID	STD	T1½	T2
1.7.20	70027	2.5	0.5.						

Start Time AM/PM

MATERIALS

Stock	Indicate what was used	Qty	Stock	Indicate what was used	Qty
15603	20mm Backflow Preventer		15401	15mm Kent Meter	
15604	25mm Backflow Preventer		15402	20mm Kent Meter	
	32mm Backflow Preventer		15901	15mm Dual Check Value	
14102	20mm Ball valve		15902	20mm Dual Check Value	
14103	25mm Ball valve		30131	25mm female adaptor threaded	1
14112	20mm Y Strainer		18205: 50mm T/B 20% PVC		
14113	25mm Y Strainer				
19732	Meter box (standard or rev taper)	1			
15415	Composite Manifold	1			
15414	Composite Meter	1			
18501	Self tapping ferrule (20mm)	1			
10702	25mm Compression Pipe	3.2			
30122	25mm Compression Male	1			
20040	Ceelon Tape	1			

Old Meter No:	Reading:	Old meter Type:
New Meter No:	Reading: 00000	Old Meter Inst Date:
 20MC267917		

Mains Diameter (mm) **50mm PVC**

Service Line Diameter (mm) **25mm**

Service Line Type **MDFE**

Pipe Length (m) **3.2**

Flow Rate

Pressure

WSL: 174413
meter 174414

1950123.671/5791967.920

PLANT/VEHICLES


Date	Plant No	Start Km/hrs	Stop km/hrs	Unit Rate	Total km/hrs
	4111				8 Km's.

OUTWORK/CONTACTOR

Date	Order No	Item Description	Contractor Code	Quantity	Unit Price

SCHEMATICS

L/H side	House No	R/H Side
Boundary line		Boundary line



Comments:

INSTALLED AS REQUESTED.

