

ELECTRICAL CERTIFICATE OF COMPLIANCE
AND ELECTRICAL SAFETY CERTIFICATE

Reference/Certificate ID No: E12325/1479

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Details:

101 KELLY STOR MATARANGI

Contact Details:
(Name and address)

CROAWELL

Name of
Electrical worker:

STEVE MOORE

Registration/Practising
licence number:

E12325

Organisation/company:

STEVE MOORE ELECTRICAL

Phone and email:

whiti-fisho@ihug.co.nz

CoC

Type of work:

 Additions Alterations New work

The prescribed electrical work is:

 Low risk General High risk (Specify):

Reference Standards:

 Part 1 of AS/NZS 3000 Part 2 of AS/NZS 3000 Additional Standards:

Description of Work: (including date/s of work and type of supply system)

INSTALL MAINS/MAN EARTHING SYSTEM/DISTRIBUTION BED
PPS, NIGHTS, DOWN, EXTRACT FANS AS PER OWNERS
REQUEST RCD2 15.9ms 24mA RCD1 15.7ms 24mA
237V 50Hz ELI-0.52R PSC455A

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

Select those that apply:

- Has been installed in accordance with the specified certified design¹
- Has an earthing system that is correctly rated (where applicable)
- Contains fittings that are safe to connect to a power supply
- Relies on a supplier Declaration of Conformity¹
- Relies on a manufacturer's instructions¹
- Has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010
- Is safe to connect

Electronic/Other reference:

Certifier's signature:

Test Results	
Polarity (Independent earth):	<input checked="" type="checkbox"/>
Insulation resistance:	+50MΩ
Earth Continuity:	0.00Ω
Bonding:	0.00Ω
Fault Loop impedance	AS AS per
Other (specify):	

Date:

21/12/21

¹ Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

ESC

I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's
name:

MANN SHEENA

Registration/Practising
licence number:

I268126

Certifier's
signature:Certificate
Issue Date:

21/12/21

Connection
Date:

21/12/21