



constructure
structural engineering

SITE INSTRUCTION

Contract 13 Hart Place
Lake Colaridge

Date 12.02.2020

No: 02

File: 10747

PROGRESS

pie pool foundation & slab
No one on site.
Bc 192333

INSTRUCTIONS & COMMENT

D12 long bars correct with D10 starter at 400
& mesh is s6b2 throughout ensure its
centrally located or Top 1/3

Section B requires cast in bolts.
external post footing lift steel to be above
bow mac bracket.

5th slab thickening required

strip footing & 140 nib correct (cast in bolts
would help).

book with office when ready.
rc inspection required.
Bob Thompson.

COPIES TO: Steve / Hamish / S. Lehn

- A No Variation
- B Contract Variation