



constructure
structural engineering

SITE INSTRUCTION

Contract ^{Lot 5}
13 Hart Place
Lake Coleridge

Date 30.01.2020 No: 01
File: 10747

PROGRESS

Bearing to single pour 3604 foundation + slab
Contractor on site. 80% complete

INSTRUCTIONS & COMMENT

1.6^{NO} scale penetrometer tests
results less than expected 100 kpa ultimate
bearing. Slab organic free

widen base to 400mm all steel to remain
as detailed

clear photo to john@constructure.co.nz

 John England

COPIES TO: 

- A No Variation
- B Contract Variation