



constructure
structural engineering

SITE INSTRUCTION

Contract 13 Hart Place
Lake Coleridge

Date 12.02.2020

No: 02/A
File: 10747

PROGRESS

pre pour foundation & slab
No one on site.
Bc 1912333

INSTRUCTIONS & COMMENT

D12 long bars correct with D10 starters at 400
& mesh is 362 throughout ensure its
centrally located or Top 1/3

Section B requires cast in bolts.
external post footing lift steel to be above
bow max bracket.

5th slab thickening required

strip footing + 140 rib correct (cast in bolts
would help).

book with office when ready.
re inspection required.

Sal Kempall.

A/ clear photos received showing photos of thickening
appear correct ok to proceed
Sal Kempall.

COPIES TO: Steve / Hamish / Site box.

A No Variation
B Contract Variation