

Inspection Site Notice

Consent No: **211186**
Applicant: **Kelly Louise Morrison**
Valuation Ref: **29820/345.05**
Site Address: **12 Kakapo Street Gore 9710**
Work Type: **Fire Installation - Freestanding Masport Hurunui**
Email To:

16 May 2024

Inspection Type: **Final Heating - Solid**
Inspection Status: **Pass**
Inspected By: **Gillian Bedwell**
Inspection Date: **16 May 2024**

Passed Items

Solid Fuel Heater
Smoke alarms

Inspection record update 16/5/2024
Form 6 received and accepted. Approved for CCC.
Please note . This Masport installation instruction for the flue system installed has been added to CCC documents section as this document appeared missing from the BC information.

x3 Smoke Alarms (S/A) in passage and within 3m of a sleeping space door and x1 in the south bedroom. These were tested and working at time of inspection. Type 1 smoke alarms with hush facilities.

Approved to test light.