ELECTRICAL WORKERS REGISTRATION BOARD
Safety • Competency

EWRB 551

Electrical Certificate of Compliance

for prescribed electrical work that is carried out on electrical installations and involves the placing or positioning or the replacing or repositioning of conductors (including fittings attached to those conductors).
To be completed whether or not an Inspection is required.

No. 2061716

No. of attachments

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer M & H MAY Phone:

Address of installation GEORGE ST, Greraldine

Postal address of customer (if not as above)

WORK DETAILS

10	No. of lighting outlets	—	No. of ranges	Please tick (✓) as appropriate where work includes:	
9	No. of socket outlets	—	No. of water heaters		Mains		Main earthing system
Was any installation work carried out by the homeowner?		— Yes	✓ No		Switchboard		Electric lines

Description Re route power + lighting cables for kitchen renovation. Extend existing lighting circuits for new light fittings. Renew fittings as necessary.

It is recommended that test results be recorded here:

- Visual Examination ✓
- Earth Continuity ✓
- Bonding ✓
- Polarity ✓
- Insulation Resistance ∞ Mohm
- Other loop test 0.64 Ω

If necessary attach any pages with sketches of work done

CERTIFICATION OF WORK

I certify that the above electrical work has been carried out in accordance with the requirements of the Electricity Act 1992 and Electricity Regulations 1997.

ELECTRICAL WORKER DETAILS

Name	G. TOWNSHEND
Registration no.	E18417
Company	TOWNSHEND ELECTRICAL LTD
Signature	
Date	1-9-06
Contact Ph No.	027 3322 363.

CERTIFICATION OF ELECTRIC LINES

(to be completed where a separate electrical worker has installed the electric line portion of the mains)

Name	
Registration no.	
Company	
Signature	
Date	
Contact Ph No.	

INSPECTION DETAILS Electrical work requiring inspection by a registered electrical inspector

☐ New mains ☐ Switchboard ☐ Earthing system ☐ Install in h

I certify that the inspection has been carried out in accordance with the requirements of regulation 41 of the Electricity Regulations 1997

Name	
nature	
Registration no.	
Date	
Contact Ph No.	

Approved by the Electrical Workers Registration Board (PO Box 10-156, Wellington. Freephone 0800 66-1000) for the purposes of the Electricity Regulations 1997.

EWRB 551

Electrical Certificate of Compliance

No. 3437231

for a low voltage installation if prescribed electrical work has been done on any part of it and the prescribed electrical work involved placing, replacing, or repositioning conductors or fittings attached to conductors.

No. of attachments

To be completed whether or not an Inspection is required.

Electrical Workers Registration Board — Safety • Competency

Electrical Workers Registration Board (PO Box 10-240, Wellington) Freephone 0800 80 1000 for the purpose of the Electricity (Safety) Regulations 2010.

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer: H + M MAY — Phone:

Address of installation: 16 GEORGE ST, GERALDINE

Postal address of customer (if not as above):

DECLARATION OF CONFORMITY (Please tick (✓) appropriate boxes)

In accordance with Regulation 58 of the Electricity (Safety) Regulations 2010, the design of the installation or part of the installation to which this certificate applies

(a) complies with either Part 2 of AS/NZS 3000:2007 ☑ or Part 1 of AS/NZS3000:2007 and Regulation 59 ☐ and

(b) the supply system of the installation or part of the installation to which this certificate applies is 230V/400 V MEN ☑ or attached other system ☐

WORK DETAILS

7 No. of lighting outlets — No. of ranges

10 No. of socket outlets — No. of water heaters

Was any installation work carried out by the homeowner? Yes ☐ No ✓

Please tick (✓) as appropriate where work includes:

Mains ☐ — Main earthing system ☐

MEN Switchboard closest to point of supply ☐ — Electric lines ☐

Description of work carried out (If necessary attach any pages with work done)

Replace rubber cables as necessary and install cabling for general power and lighting circuits. Install new fittings.

CERTIFICATION OF WORK (Please tick (✓) appropriate boxes)

I certify that the completed installation or part of the installation to which this certificate applies

- ☑ has been installed in accordance with the design detailed in the Declaration of Conformity section above
- ☑ has had tests which are required by the Electricity (Safety) Regulations 2010 satisfactorily completed
- ☑ has an earthing system that is correctly rated
- ☑ contains fittings which are safe to connect to a power supply
- ☑ is safe to connect to a power supply

ELECTRICAL WORKER DETAILS

Name: G. TOWNSHEND — Registration No.: E18417

Company: TOWNSHEND ELECTRICAL — Contact Ph No.: 027 3322363

Signature: [signature] — Date: 5-8-2011.

INSPECTION DETAILS

Electrical work requiring inspection by a registered electrical inspector

☐ Mains work (mains, MEN switchboards closest to the point of supply, or main earthing systems) ☐ Attached other ☐ Work carried out in accordance with Part 1 of AS/NZS 3000:2007

I certify that the items identified above are electrically safe and that the inspection has been carried out in accordance with the Electricity (Safety) Regulations 2010.

Name — Registration No.

Signature — Date

Contact Ph No.

CUSTOMER COPY - THIS IS IMPORTANT

ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID NO: TEL 852

This Electrical Safety Certficate provides a legally recognisable statement that the connected installation or part installation, or any fitting that supplies an installation or a part of an installation, is safe to use following prescribed electrical work.

Location Details: 16 GEORGE STREET, GERALDINE

Contact Details: (Name and address) H MAY, as above

Details of work: ☐ The whole installation ■ Part of the installation

Description of work:

RENEW ELECTRICAL FITTINGS IN LAUNDRY

Date of connection: 10-10-2016

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name: G TOWNSHEND

Certifier's signature:

Email:

027 3322363

Registration/Practising licence number: E18417

Certificate Issue Date: 10-10-2016

Organisation/ Company: TOWNSHEND ELECTRICAL

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.

VER 23/05/14

TOWNSHEND ELECTRICAL LTD

PO Box 39
GERALDINE 7956

Ph 693 7088
Mobile 027 3322 363

Tax Invoice/Statement

H May
16 George St
Geraldine

Job Card Reference	719
Invoice Number	INV00914
Invoice Date	05/08/2014
GST Reg. Number	93-550-080

Code	Description	Quantity	Units	Unit Price	Price
	Install cables and fittings for new brewery and woodshed. Replace garage fluorescent light fitting.				
2.52CE	2.5mm 2C&E TPS	29	MTR	2.80	81.20
2.52CRW	2.5mm 2C TPS RED & WHITE	8	MTR	6.85	54.80
2.5CWBK	2.5mm CONDUIT WIRE BLACK	15	MTR	3.47	52.05
2.5CWR	2.5mm CONDUIT WIRE RED	15	MTR	3.47	52.05
C25	CONDUIT 25MM	16	MTR	7.36	117.76
9025TCM	FLEXIBLE CONDUIT 25MM	10	MTR	6.75	67.50
GHS25	GALVANISED HALF SADDLE 25MM	58	EA	0.73	42.34
SB25	SOLID BEND 90 DEG 25MM	2	EA	5.85	11.70
IT20	INSPECTION T 20MM	2	EA	8.32	16.64
JB253	JUNCTION BOX 25MM 3 WAY	3	EA	8.62	25.86
51MB	SOCKET OUTLET ROUND 10A 3PIN C/W MOUNTING PLATE	1	EA	15.80	15.80
89DI	DOUBLE INSULATED MOUNTING BLOCKS	4	EA	15.35	61.40
682	DBL GANG SWITCH	1	EA	29.70	29.70
695	DBL SOCKET OUTLET 10A HORZ	3	EA	36.40	109.20
PPZ258	THORN DBL BATTEN FLUORO	2	EA	70.00	140.00
58W84	FLUORO TUBE, 58W 840	4	EA	7.50	30.00
LHT0007	TWIN FLOODLIGHT PAR38 ES BLACK	1	EA	46.93	46.93
QHF560B	TWIN SPOT PIR SENSOR BLACK	1	EA	63.69	63.69
120WPAR38FLOOD	120W PAR38 LAMP ES FLOOD	4	EA	11.38	45.52
DC2025	CONNECTOR, FLEX. CONDUIT TO CONDUIT 25MM	1	EA	9.25	9.25
11357	MCB 20A 1P 4.5KA	1	EA	19.90	19.90