GAS SAFETY & COMPLIANCE CERTIFICATE

MENZIES GROUP LTD 6 HIGH STREET TIMARU PHONE 03 6848440

Reference No: 109705 HRR-00001897TQ0V

Gas Safety Certificate and Certificate of Compliance made pursuant to Regulations 46 and 52B of the Gas (Safety and Measurement) Regulations 2010 (as amended), and Energy Work Certificate made pursuant to Regulation 19 of the Building Act 2004.

CLIENT	HELEN MAY	BUILDING CONSENT #	
ADDRESS		INSTALLATION ADDRESS	16 GEORGE STREET GERALDINE

DESCRIPTION AND LOCATION OF THE GASFITTING:

INSTAL A REPLACEMENT GAS HOB BOSCH PCH6A5B904 31.3 MJ/HR AND CONNECT TO THE 9KG CYLINDER GAS SET UP OUT SIDE

GAS TYPE	LPG	GAS SUPPLY PRESSURE	2.75 Kpa
DATE(S) GASFITTING PERFORMED	Date 09/10/2020	DATE OF GAS CONNECTION	

STANDARD RISK CLASSIFICATION (tick one): [ ] Low [ ] General [✓] High

NAME, REGISTRATION NUMBER (IF ANY) OF PERSONS WHO CARRIED OUT GASFITTING UNDER SUPERVISION:

Name KEIRAN RYAN Name

Registration number 28179 Registration number

CERTIFICATE ATTACHMENTS (tick as applicable)

[ ] Manufacturers Instructions: Enter details of any attachments

[ ] Certified Designs: Enter details of any designs

"I believe on reasonable grounds that:

(a) the gasfitting work described above has been done lawfully and safely; and

(b) the work has been done in accordance with (tick one):

[✓] **sections 3 to 6 of AS/NZS 5601.1, or**

(c) the work [ ] has [ ] has not (tick one) been done in accordance with a certified design; and

(d) the work done [ ] has [ ] has not (tick one) relied on any manufacturers instructions; and

(e) this certificate relates to the [ ] whole [ ] part (tick one) installation described above; and

(f) the gas installation is connected to a gas supply and is safe to use; and

(g) the information contained in this certificate is correct."

CERTIFIER NAME	Stuart Loveday
REGISTRATION TYPE & NUMBER	06872
SIGNATURE	
DATE	13/10/2020

Master Plumbers Gasfitters Drainlayers