



"This document has been supplied to Arizto Limited (the Agency) by the vendor or a third party and is merely passing this information over. The Agency has not verified the information nor warrants its accuracy. The Agency is hereby indemnified of any errors in the document and will not be held accountable for any persons who rely on this document to complete their own due diligence. We recommend you seek your own independent legal and/or technical advice."



T: 0800-333-212
E: info@fibresafe.co.nz
www.fibresafe.co.nz

Fibresafe NZ Ltd, Level 1, 16 Armidale Street, Petone, Lower Hutt, 5012



Analysis Report - Asbestos in Bulk Materials

Client Number:	1287	Date Received:	6/10/2025
Client:	Claire & Ynys Haugh	Lab Job Ref:	WAB2510018
Contact Details:	12 Kakahu Street	Client Job Ref:	N/A
	RD26	Sampling Date:	N/A
	Temuka 7986	Analysis Date:	6/10/2025
		Date Reported:	8/10/2025
Samples analysed in accordance with AS 4964-2004 Method for the qualitative identification of asbestos in bulk samples using a combination of low powered stereomicroscopy and polarised light microscopy with dispersion staining at Fibresafe NZ, Level 1, 16 Armidale Street, Lower Hutt. Limit of detection 0.1g/kg or 0.01% w/w.			

Sample Name	Lab Reference	Sample Weight and/or Size *	Category *	Analysis Results
Roof tile	WAB2510018-1	1.5 g	Other	No Asbestos Detected.

*** Analysts Comments:**

Unless otherwise stated, sampling of materials was conducted by the client and analysis results relate only to samples as received by the laboratory. Samples are held at the laboratory for a period of 6 months. Once the storage period has expired, samples will be discarded unless otherwise requested by the client. This laboratory is accredited by International Accreditation New Zealand (IANZ) and all results provided are from analysis conducted in accordance with the terms of accreditation, with the exception of those marked *. This report cannot be reproduced, except in full, without the written permission of the Laboratory.

James Lord
Technical Quality Manager