



Compliance and Electrical Safety Certificate

Unique ID: 23542.1/E266249

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

(1) Location of Installation or Part Installation

Address: 106 Freyberg Road, Ruawai, Ruawai 0530

(2) Customer / Occupier / Owner Information

Name: Albert Harrison

Address: 106 Freyberg Road, Ruawai, Ruawai 0530

Email: kebab@ps.gen.nz

Phone: _____

(3) Electrical Worker Information

Name: Nick Juretech

Registration/Practising Licence No.: E266249

Organisation: C & C Contract Electrical Limited

Phone: 021 540 637

Email: nickjuretech@gmail.com

Name of person(s) being supervised: Cheyene Williams(EW16189)

(4) Work Details

This work is: ☐ Is New Work ☐ Is Addition ☒ Is Alteration ☐ Is Maintenance

The prescribed electrical work is: ☐ Home Owner ☐ Low Risk ☐ General ☒ High Risk

High Risk Specified: A+ men inspection

Reference Standards: ☐ Part 1 of AS/NZS 3000 ☒ Part 2 of AS/NZS 3000 ☐ AS/NZS 3012
☐ Additional Standards _____

Indicate the number of each item installed or altered:

Lighting Outlets: 1 Socket Outlets: 2 Ranges: 1 Water Heaters: _____

Work Done: Move men switchboard from the hallway to the laundry. Join short cables in the ceiling and add in the new powerpoint circuit below the board

The work was done within the period: Date Commenced: 14/08/2025 Date Completed: 14/08/2025

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- | | |
|---|---------------------------------------|
| ☒ Relies on manufacturer's instructions | ☐ Attached/Ref |
| ☐ Relies on Declaration of Conformity | ☐ Attached/Ref |
| ☐ Accordance with certified design | ☐ Attached/Ref |

Reference: www.electroquip.co.nz

- | |
|---|
| ☒ Tested in accordance with ESR2010 |
| ☒ Earthing system that is correctly rated |
| ☒ Fittings safe to connect |
| ☒ Safe to connect to a power supply |

Test Results	
Continuity of Earthing System:	0.01
Insulation Resistance:	350m
Polarity – Correct Circuit Connections:	Correct
Verification of Impedance:	0.35
Bonding:	0.01
Other:	Rcd tests

Signature: _____

Date: 14/08/2025

(6) Electrical Safety Certificate

(to be completed by the person who connects the installation, or part installation to the power supply)

I certify that the installation, or part of the installation as described above, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use. If maintenance, alteration or addition, has not adversely affected any other part of the installation.

Name: Nick Juretech Registration/Practising Licence No: E266249

Signature: _____

Issue Date: 14/08/2025

Connection Date: 14/08/2025