

Details		
Date: 11th October 2017	Time: 10:27 PM	Day: Thursday
Persons present on property during issue of notice		Yes
Full Name	Robert Clark	
Physical Address	866 Omamari Rd, Omamari 0373	
Telephone Number	09 439 6433	

CHECKLIST			
SEPTIC TANK			COMMENTS
Inlet/outlet pipe in place	Yes		
Is there an effluent filter fitted?		No	
Inlet/outlet pipe correct height	Yes		
Outlet pipe restricted		No	
Tank lid fitted	Yes		
Mushroom in place	Yes		
Access unobstructed		No	
SOAKAGE FIELD			
Evidence of effluent run-off		No	
Excessive growth on soakage field		No	
GREASE TRAP			
Is there a grease trap fitted?		No	
Type of grease trap			
Is grease trap connected ?			
ADDITIONAL DETAILS			
ADDITIONAL NOTES:			
Septage removed: 2.5 m ³		Where was the septage disposed? Whangarei	
Further investigation by Council required: No			
Contractor's name: The BogDoc		Signed: 	
Contractor's telephone number: 09 433 7113			
Bylaws can be viewed at Council offices and online at www.kaipara.govt.nz			