

This Electrical Safety Certificate provides a legally recognisable statement that the connected installation or part installation, or any fitting that supplies an installation or a part of an installation, is safe to use following prescribed electrical work.

Reference 33621

Client Name Neil Mills

Client Address 133 Sumnervale Drive, sumner, 8081, Christchurch

Site Address 133 Sumnervale Drive, sumner, 8081, Christchurch

Description of Work

Installation Type Part Installation

Connection Date 15 September 2026

Work Description Replace Garage Sub Board.

Declaration

I certify that the installation, or part installation to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Electrician Stephen Boulton

Registration I 062371

Email info@atlelectrical.co.nz

Company ATL Electrical



Certifiers Signature

15 September 2026

Date of Certification

Testing Results - Earthing Tests

Circuit ID	Visual	Earthing Type	Earth Continuity	Earth Loop
earth garage	No	Main Earth	0.3Ω	

Testing Results - RCD Tests

Circuit ID	Visual inspection	Voltage	Amps	PSC	Live Neutral	Live Earth	Neutral Earth	RCD Rated Current	AC Waveform	Tripping Time x1/2	Tripping time x1	Tripping time x5	Tripping Current
garage	Yes				Yes	Yes	Yes	30mA	0°C		25.2ms	6.6ms	
garage	No		16A		Yes	Yes	Yes	30mA	180°C		15ms	13.8ms	



Photo Attachments of Work

